



STORAGE TANK DIVISION

Have You Checked Your Tank System Today ?

C
H
E
C
K
L
I
S
T

- ✓ Spill Protection (Maintain sump free of liquids)
- ✓ Overfill Protection (Check alarms and automatic shutoff devices)
- ✓ Corrosion Protection (Tank and Piping)
 - Galvanic
 - Within 6 months of installation
 - Every 3 years after installation
 - Impressed Current
 - Within 6 months of installation
 - Every 3 years after installation
 - Check rectifier operation every 60 days
- ✓ Release Detection
 - Monthly monitoring
 - Annual piping test and line leak detector tests
 - Daily inventory
 - Statistical Inventory Reconciliation
 - Automatic tank gauging
 - Other approved methods
- ✓ Maintenance
 - Daily systems check
 - Periodic equipment check
 - Dispenser Sumps
 - Liquid level sensors
 - Piping and tank sumps
- ✓ Record Keeping
 - Tank and piping tightness test (5 years)
 - Performance claims for release detection (5 years)
 - Sampling, testing, monitoring (2 years)
 - Calibration, maintenance and repair of release detection equipment (2 years)
 - Schedules of required calibration and maintenance for release detection equipment (5 years)

Questions? Ask us!

DEQ-STD-TANKS@state.mi.us

1-800-662-9278

www.deq.state.mi.us/std

Pollution Emergency: 1-800-292-4706